

**GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIVISIONAL FIRE OFFICER  
WEST BENGAL FIRE & EMERGENCY SERVICES  
VILL- DHARINDA, P.O/P.S-TAMLUK, WARD NO.-20 PIN-721636**

Memo No : IND/WB/FES/20222023/44359

DATE: 22/04/2022

**From:**  
The Divisional Fire Officer  
Fire Preventing Wing,  
West Bengal Fire & Emergency Services.

**To,**  
The Royal International School,  
Vill-Santipur,P.O-Mecheda,Dist- Purba Medinipur,Pin-721137,W.B

**Sub:-** Fire safety Certificate of an existing G+2 storied school building under group of Educational Building as per NBC Part-IV , in the name & style of "The Royal International School" at Vill-Santipur, P.O-Mecheda, Plot No-RS 2393,LR 2429, JL No-3, P.S-Kolagaht, Dist-Purba Medinipur, Pin-721137.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactory working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up keep the fire Safety Measure of the aforesaid building the following safety measure need to be incorporated / maintained.

1. However to up-keep the Fire Safety measure of the aforesaid institutional building the following measures are to be incorporated.
  - 1) Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No Parking will be allowed on the Driveway.
  - 2) Booster Pump 05 HP and Down Corner MS Pipe line shall be enhanced by 100 MM within 3 months otherwise the next renewal will be suspended.
  - 3) The interior finish decoration of building shall be made with low flame spread material conforming to the IS Specification.
  - 4) To eliminate risk of Fire Hazards, good House Keeping both for insides and outside of the building shall be strictly maintained.
  - 5) Electrical wiring of the whole building shall have to be carefully checked for any where any tear in them, particularly lines having false ceiling and ducts.
  - 6) The notice of Fire Fighters and Evacuation from the building shall be prepared and displayed at all venerable of the building.

- 7) The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
- 8) Mock Fire Practice and evacuation drill shall be performed periodically with Participants of all the occupants of the building.
- 9) Transformer and Switch Gear room shall be protected with automatic Co2/ D.C.P Fire extinction conforming IS specification.
- 10) First-Aid Fire Fighting system shall be provided as per IS specification.
- 11) Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all times.
- 12) Periodical flashing of water in the Hose Reel Hose line shall be made to maintain the efficiency working performance of above mention system.
- 13) If required the old lines shall have to be replace with new lines cables shall always be laid in M.S conduct pipes continuously bounded to the earth.
- 14) The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
- 15) This Fire Safety Certificate is valid for three years and has to be renewed in every three year from the date of issue of letter Vide Notification No.-568\_L dated 20.12.2021 and Memo No.- WBFES/344(200)2922 dated 12.03.2022.
- 16) The Renewal of Fire Safety Certificate is to be obtained from the Divisional Fire Officer, Purba Medinipur Division, West Bengal Fire and Emergency Services performance of all the life and Fire Safety arrangements and installations of the building.

**Divisional Fire Officer**  
**West Bengal Fire & Emergency Services**

**Signature valid**

Digitally signed by SUNIL  
KUMAR MONDAL  
Date: 2022.04.27 14:20:52  
IST