



Government of West Bengal
West Bengal Fire & Emergency Services
Midnapur Fire Station, Sepoy Bazar, P.O-Medinipur, P.S-Kotwali, Pin-721101

CERTIFICATE

Memo no.: FSR/IND/WB/FES/202520266259

Dated: 05-03-2025

From,
Divisional Officer,
Paschim Medinipur,
West Bengal Fire & Emergency Services

To,
The Royal International School,
Vill-Santipur, P.O-Mecheda, Dist-Purba Medinipur, West benagl, Pin-721137

This Certificate on Fire Safety is electronically auto-generated in favour of Mr. Giyaul Hoque, with Aadhar No 641332602724 of Company/ LLP/ Trust/Society etc An existing educational building G+3.G+2&G+2 storage building at the same premises of "The Royal International School" Favour of GIYAU HOQUE, CHAIRMAN JL No. 3 DAG No. LR-2010 Fire Safety Certificate (FSC) with PAN ABMPH7896L Address Santipur Purba Medinipur Pincode- 721137 on the basis of the Self-Declaration submitted by the Applicant/ Owner/ Occupier/ Company/ LLP/ Trust/ Society etc. in Form No Form3 being covered under the Govt. Notification No. 1961/FES/O/C-1/MISC-08/2023 Dated 05/03/2025, for the following occupancy.

- 1.Type of occupancy: Schools, Colleges, Training Institute (stand alone)
- 2.Sub-type: Educational B-1
- 3.Height of the Building: 9
- 4.Area of occupancy: 500
- 5.Validity date: 04-Mar-2028
- 6.Next date of renewal: 27-Jan-2028 onwards

This certificate is auto-generated on the strength of Self-Declaration duly signed and uploaded by the applicant and it dispenses with the Fire Safety Certificate (FSC) as required under section 11C of the West Bengal Fire Services Act, 1950 being small business entity and/or falling in the low risk category as stated above.

The Applicant shall have to maintain all the Fire Prevention and Safety Measures in good repair and in efficient condition at all time, as mentioned in his/her Self-Declaration and he/she will remain fully responsible for maintaining and operating the same, failing which the Department of West Bengal Fire & Emergency Services has all liberty to take any legal action against the Applicant as per the provisions as laid down in the West Bengal Fire Services Act, 1950 with up to date amendments.

The Departmental officers will have the right to inspect anytime to see that the contents of self certification are true. For submission of any false information or wrong credentials in the submitted declaration, this Certificate on Fire Safety will deemed to be treated as cancelled and the Department of West Bengal Fire & Emergency Services may initiate legal action against the Applicant as per the provisions as laid down in the West Bengal Fire Service Act, 1950 with up to date amendments. The validity of this self-certification is for one year only and uploading of a fresh and updated self certification is needed at least one month before the expiry of validity of existing self

Recommendation:

On Conditional Fire Safety Certificate allow, subject to comply the condition within two months from issuing of this certificate and intimate to this end with photograph.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Third Party Certificate Verification' link and keying in Unique Number : 211922506300008425

Other General recommendation are as follows:-

1. Entrance/Exit as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
2. Driveway must be free of any type of obstruction for easy movement of Fire appliances. No parking will be allowed on the driveway.
3. To eliminate risk of Fire Hazards, good housekeeping both for inside and outside of the building shall be strictly maintain.
4. Existing electrical wiring and Fire Fighting installation of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above falls ceiling and ducts.
5. A Fire control room including CCTV system shall have to maintain which observe all the floors of the building.
6. Transformers, switch gear, main and meter room shall be protected which CO2 or DCP Fire Extinguisher confirming I.S. Specification.
7. All fire protection and detection system must be maintain as per Fire Service colour code.
8. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
9. Emergency lighting system (Battery backup) to be installed in the staircase for the safe evacuation.
10. Electrical audit shall be conducted in every year and a certificate must be submitted in this office at the time of renewal of Fire Safety Certificate.
11. First aid Fire Fighting System shall be provided as per S.I Specification.
12. A crew of trained fire man under an experienced officer shall be maintained round the clock for the Fire Safety of the building.
13. A notice Fire Fighting and evacuation on the building shall be prepared and displayed at all vulnerable places of the building.
14. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
15. Fire License shall have to be obtaining for storing and processing of LPG and other highly combustible or inflammable articles.
16. Fire Safety Certificate is valid for a period of 3 years from the date of issue and has to be renew after 3 years certifying about the satisfactory service, performance of all the life and life safety arrangements installation of the building.
17. Any changes /exception/deviation of use group/ownership etc information must be communicated to this department.
18. In case of any land dispute/litigation if arise any time this Dept. has no liabilities and responsibilities.

On compliances of all the above Fire and Life safety recommendations, the Director General West Bengal Fire & Emergency Services shall be approached for necessary inspection and testing of the installation. Fire Safety Certificate in favour of the above said occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

Valid Upto: 04-MAR-2028



Validity unknown

Digitally Signed
Name: Bam Kumar Chowdhury
Date: 05-MAR-2025 21:30:54
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Third Party Certificate Verification' link and keying in Unique Number : 211922506300008425